

Our Ref: HL/M1301073  
Test Report: M105480

4<sup>th</sup> June 2013

Guarniflon SpA.  
Via T. Tasso, 12,  
24060 Castelli Calepio (BG),  
Italy

**WATER REGULATIONS ADVISORY SCHEME (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**POLYTETRAFLUOROETHYLENE (PTFE) – COMPONENTS**

**5294**

G439. Terracotta coloured, extruded PTFE pipe. For use with water up to 85°C.


**APPROVAL NUMBER: 1304527**  
**APPROVAL HOLDER: GUARNIFLON SPA.**

The Scheme reserves the right to review approval. This approval is valid between April 2013 and April 2018.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully



Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme